


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No:.....

Dated: 28/07/2025

It is certified that an inspection team headed by DR. TARUN CHAUDHARY (Name of Officers with designation) from CHC UNM inspected the **Dewasthali Modern Gurukul, Hathchhoya (Shamli) 247778** (Name & Address of the school) on 28/07/25 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 1981 dated 25-06-2025 of **District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Shamli (PHED Lab)** certified that the **Dewasthali Modern Gurukul, Hathchhoya (Shamli) 247778** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One Year

Signature with Seal: Name : Dr. Tarun ChaudharyDesignation : M.S. UNM UNMName & Address of the Office / Department : CHC UNM
SHAMLI

To,
Dewasthali Modern Gurukul,
Hathchhoya (Shamli) 247778
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

For

Dewasthali Modern Gurukul

Pinkie

Manager

K.S. Gaur
SUDHIRPrincipal
Dewasthali Modern Gurukul
Hathchhoya, Shamli (U.P.)



District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Shamli



TC-13814

Test Report (Water)

Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Shamli Uttar Pradesh, India

Report No.	1981	Date:	25/06/2025	Page No. 01
Customer Name	Dewasthali Modern Gurukul			
Office Name and Address	Dewasthali Modern Gurukul Hathchhoya (Shamli)			
Ref Letter No & date	0 Dt-23/06/2025			

Basic Details of Sample

District	Shamli	Block	Un
Gram Panchayat	Hathchhoya	Village/Vard	Hathchhoya
Habitation/Mohalla	Hathchhoya	Location/Site name	Devasthali Modern School
Water Source	Submersible	Sample No.	SML-1981
Quantity of Sample (ml)	1 ltr	Date of Sample Collect.	24-06-2025
Receiving Date	24-06-2025	Sample Collector	Sudhir Kumar
Sample Depositor	Sandeep Kumar	Sampling Method	IS 17614 (Part 1):2021
Analysis Strat date	24/06/2025	Analysis completion date	24/06/2025

Technical Data Analysis

S. No.	Analysis Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5):2021
2	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 7):2023
3	pH	-	7.11	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022
4	Colour	Hazen	3.5	5	15	IS 3025 (Part 4):2021
5	Turbidity	NTU	0.48	1	5	IS 3025 (Part 10):2017
6	TDS	mg/L	396	500	2000	IS 3025 (Part 16):2023
7	Chloride	mg/L	42	250	1000	IS 3025 (Part 32):2019
8	Total Alkalinity	mg/L	428	200	600	IS 3025 (Part 23):2023
9	Total Hardness	mg/L	284	200	600	IS 3025 (Part 21):2019
10	Sulphate	mg/L	23.39	200	400	APHA 24 th 4500 SO4 E. Turbidity Method:2023
11	Nitrate	mg/L	0.853	45	45	APHA 24 th 4500 NO3 B. UV Spec Method:2023
12	Fluoride	mg/L	0.181	1	1.5	APHA 24 th 4500-F.C. Electrode Method:2023
13	Iron	mg/L	0.27	1	1	APHA 24 th 3500 Fe B. P. throline Method:2023
14	Calcium	mg/L	76.51	75	200	IS 3025 (Part 40):2019
15	Magnesium	mg/L	23.32	30	100	IS 3025 (Part 46):2023

- Note
1. This Certificate refers only to the particular sampler(s) submitted for testing.
 2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
 4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless

Prepared by Reviewed by

For

Dewasthali Modern Gurukul

Pmki
Manager

SUDHIR
Principal

Dewasthali Modern Gurukul
Hathchhoya, Shamli (U.P.)

Authorized by

District Level Water Analysis Laboratory
Shamli

End of Report

Laboratory Contact Details: Email-Id: upinlabshamli@gmail.com, Mobile no.: +91 9528906867, +91 9897823744



District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Shamli

Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Shamli Uttar Pradesh, India

Report No.	1981	Date:	25/06/2025	Page No. 01
Customer Name	Dewasthali Modern Gurukul			
Office Name and Address	Dewasthali Modern Gurukul Hathchhoya (Shamli)			
Ref Letter No & date	0 Dt-23/06/2025			




Basic Details of Sample

District	Shamli	Block	Un
Gram Panchayat	Hathchhoya	Village/Vard	Hathchhoya
Habitation/Mohalla	Hathchhoya	Location/Site name	Devasthali Modern School
Water Source	Submersible	Sample No.	SML-1981
Quantity of Sample (ml)	1 ltr	Date of Sample Collect.	24-06-2025
Receiving Date	24-06-2025	Sample Collector	Sudhir Kumar
Sample Depositor	Sandeep Kumar	Sampling Method	IS 17614 (Part 1):2021
Analysis Strat date	24/06/2025	Analysis completion date	25/06/2025

Technical Data Analysis


S. No.	Analysis Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
2	Free Res. Chlorine	mg/L	0.00	0.2	1	IS 3025 (Part 26):2021
3	Conductivity	mg/L	780	2000	4000	IS 3025 (Part 14):2013
4	E. Coli	CFU/100ml	0	0	0	IS 15185:2016 (RA 2021)
5	Total Coliform	CFU/100ml	0	0	0	IS 15185:2016 (RA 2021)

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
 4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

Prepared by  Reviewed by  Authorized by 

For

Dewasthali Modern Gurukul


Pinkie
Manager


SUDHIR
Principal

Dewasthali Modern Gurukul
Hathchhoya, Shamli (U.P.)

End of Report

Laboratory Contact Details: Email-Id: upnlabshamli@gmail.com, Mobile no.: +91 9528906867, +91 9897823744